



BASE OF EXCAVATION TO BE LEVEL AND FREE OF BROKEN ROCK

IF REQUIRED PREPARE A BASE OF 12mm SCREENINGS, DOLOMITE OR CONCRETE

TREATMENT TANK MAY NOT BE INSTALLED WITHIN 3.0m OF ANY BOUNDARY OR BUILDING

TANK SHOULD BE HALF FILLED WITH WATER FOLLOWING INSTALLATION TO MAXIMISE STABILITY AND STOP FLOATATION

WEIGHT APPROX. 300 kg

— EXCAVATION REQUIREMENT  
3m x 3m

NB. DEPTH OF EXCAVATION  
DETERMINED BY DRAIN DEPTH

**BIOCYCLE MODEL 10EP 6000L**